

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
07/06/2011 11:59 am

**PWS ID:** UTAH24002      **Name:** BONANZA MINES  
**Legal Contact:** AMERICAN GILSONITE COMPANY      **Rating:** Approved  
 LEE JENKINS      **Rating Date:** 11/17/1998  
**Address:** 29950 S BONANZA HWY      **Activity Status:** Active  
 BONANZA HWY, UT 84008  
**Phone Number:** 435-789-1921  
**City Served (Area):**  
**County:** UINTAH COUNTY  
**System Type:** Non Transient      **Last Inv Update:** 01/12/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 08/28/1998      **Total Dsgn Cap:**  
**Population:** 75      **Surveyor:** DDW SURVEYOR      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	JENKINS, LEE	MANAGER	435-789-1921		

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	12
			12 Total Svc Connections

### Storage

**Total Storage:** 40,000 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	40,000 GAL	Steel		A	

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	NINETEEN WELLS CHLORINATOR		A	

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	NINETEEN WELLS	Active	WL	12	150 GPM		Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.